



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6071108

Reedsport School District 105 100 Ranch Road Reedsport, OR 97467	Project: General Project #: Lead/Copper Client Contact: Attn: Dan Forbess	Date Reported: 07/19/16 Date Received: 07/11/16 10:40 Sampled By: Various
--	---	---

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6071108-01	Sample Location: Braves Center Sink									
	Lead	1030	0.006	mg/L	0.002	0.02	07/07/16 07:33	07/13/16	DJP	
	Copper		0.424	mg/L	0.010	1.3	07/07/16 07:33	07/13/16	DJP	
6071108-02	Sample Location: Jr. High Commons									
	Lead	1030	ND	mg/L	0.002	0.02	07/07/16 07:38	07/13/16	DJP	
	Copper		1.358	mg/L	0.010	1.3	07/07/16 07:38	07/13/16	DJP	CON-1
6071108-03	Sample Location: Jr. High Hall Near Room 5									
	Lead	1030	0.003	mg/L	0.002	0.02	07/07/16 07:40	07/13/16	DJP	
	Copper		0.960	mg/L	0.010	1.3	07/07/16 07:40	07/13/16	DJP	
6071108-04	Sample Location: Auditorium Lobby									
	Lead	1030	ND	mg/L	0.002	0.02	07/07/16 07:43	07/13/16	DJP	
	Copper		0.949	mg/L	0.010	1.3	07/07/16 07:43	07/13/16	DJP	
6071108-05	Sample Location: Circle Drive Drinking Fountain									
	Lead	1030	0.003	mg/L	0.002	0.02	07/07/16 07:46	07/13/16	DJP	
	Copper		0.277	mg/L	0.010	1.3	07/07/16 07:46	07/13/16	DJP	
6071108-06	Sample Location: Gym Drinking Fountain									
	Lead	1030	0.004	mg/L	0.002	0.02	07/07/16 07:49	07/13/16	DJP	
	Copper		0.794	mg/L	0.010	1.3	07/07/16 07:49	07/13/16	DJP	
6071108-07	Sample Location: Kitchen									
	Lead	1030	ND	mg/L	0.002	0.02	07/07/16 07:40	07/13/16	DJP	
	Copper		0.216	mg/L	0.010	1.3	07/07/16 07:40	07/13/16	DJP	
6071108-08	Sample Location: Gym Fountain									
	Lead	1030	0.006	mg/L	0.002	0.02	07/07/16 07:54	07/13/16	DJP	
	Copper		0.675	mg/L	0.010	1.3	07/07/16 07:54	07/13/16	DJP	
6071108-09	Sample Location: 5th&6th Grade Wing Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6071108

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.012	mg/L	0.002	0.02	07/07/16 07:58	07/13/16	DJP	
Copper			1.320	mg/L	0.010	1.3	07/07/16 07:58	07/13/16	DJP	CON-1
6071108-10	Sample Location: C.Room 14									
Lead		1030	ND	mg/L	0.002	0.02	07/07/16 08:05	07/13/16	DJP	
Copper			0.935	mg/L	0.010	1.3	07/07/16 08:05	07/13/16	DJP	
6071108-11	Sample Location: Library Entrance-Hallway Fountain									
Lead		1030	0.052	mg/L	0.002	0.02	07/07/16 08:10	07/13/16	DJP	CON-1
Copper			1.307	mg/L	0.010	1.3	07/07/16 08:10	07/13/16	DJP	CON-1
6071108-12	Sample Location: Classroom 29									
Lead		1030	0.002	mg/L	0.002	0.02	07/07/16 08:17	07/13/16	DJP	
Copper			0.614	mg/L	0.010	1.3	07/07/16 08:17	07/13/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6071108

Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.